

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00434

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): **Series of Power Supply Equipment**
(refer to attached appendix for details and conditions)
Placed on the market **Dycon Power Solutions Ltd.**
under the name or trade mark of: **Unit A, Cwm Cynon Business Park, Mountain Ash**
CF45 4ER Wales
United Kingdom

and produced in the **Dycon Power Solutions Ltd. (SG- 15023)**
manufacturing plant(s): **Unit A, Cwm Cynon Business Park, Mountain Ash**
CF45 4ER Wales
United Kingdom

Intended use: **Fire Safety**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-4:1997+A1:2002+A2:2006

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00434** on **2014-09-24** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body

0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2020-12-30

Issue: 1

Signature:



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00434

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00434

The details and conditions of use for the **Series of Power Supply Equipment**, placed on the market under the name or trade mark of:

Dycon Power Solutions Ltd.
Unit A, Cwm Cynon Business Park, Mountain Ash
CF45 4ER Wales
United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-4:1997+A1:2002+A2:2006

Model	Manufacturing Location	Description
D2431-7	SG- 15023	1.5 A Power Supply Equipment with 7 Ah Batteries in Medium Standalone Enclosure
D2433-7	SG- 15023	3 A Power Supply Equipment with 7 Ah Batteries in Medium Standalone Enclosure
D2433-17	SG- 15023	3 A Power Supply Equipment with 17 Ah Batteries in Large Standalone Enclosure
D2425-17	SG- 15023	5 A Power Supply Equipment with 17 Ah Batteries in Large Standalone Enclosure

Conditions of use:

Suitable for indoor applications only.

General Notes:

1. Evaluated under Intertek project number 101464530 and 102351153.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.